ZERTIFIKAT ◆ CERTIFICATE ◆ 認證證書 ◆ СЕРТИФИКАТ ◆ CERTIFICADO ◆ CERTIFICAT
TÜV SÜD

Product Service

CERTIFICATE

No. B 043476 0009 Rev. 00

Holder of Certificate: **Dong-A Bestech Co., Ltd.**
54, Songnae-daero, 518beon-gil
Bucheon-si, Gyeonggi-do 14445
REPUBLIC OF KOREA

Production Facility(ies): 043476

Certification Mark:

Product: **Terminal block (Terminal Lug)**

Model(s): **PPEv-0w-xRy-z**
Remark:
v. Product Part (O: One Hole Type, T: Two Hole Type)
w. Conductor Square (0.75mm² to 630mm²)
x. Barrel Form
(S: One Clamping Type, L: Two Clamping Type)
y. Stud Size (03, 04, 05, 06, 08, 10, 12, 14, 16, 20, 24)
z. Type of conductor (Blank: Stranded, F: Flexible)

Parameters:

Nominal cross-sectional area:	0.75mm² to 630mm²
Type of conductor:	Stranded / Flexible
Class of connector:	Class A

Tested according to: IEC 61238-1-3:2018

The product was tested on a voluntary basis and complies with the essential requirements. The certification mark shown above can be affixed on the product. It is not permitted to alter the certification mark in any way. In addition the certification holder must not transfer the certificate to third parties. See also notes overleaf.

Test report no.: CPSA01259419
Valid until: 2024-10-21

Date, 2019-10-29 (Harry Kwon)

TÜV SÜD Product Service GmbH • Certification Body • Ridlerstraße 65 • 80339 Munich • Germany

A4 / 07.17